

**Substance
Organics (con't)**

**Maximum Contaminant Level (MCL)
parts per million**

Endothall	0.1
Endrin.....	0.002
Ethylbenzene.....	0.7
Ethylene Dibromide.....	0.00005
Glyphosate	0.7
Oxamyl (Vydate).....	0.2
Haloacetic acids.....	0.060
Heptachlor.....	0.0004
Heptachlor Epoxide	0.0002
Hexachlorobenzene.....	0.001
Hexachlorocyclopentadiene.....	0.05
Lindane	0.0002
Methoxychlor.....	0.04
Monochlorobenzene.....	0.1
Pentachlorophenol.....	0.001
Picloram	0.5
Polychlorinated Biphenyl (PCB)	0.0005
Simazine.....	0.004
Styrene	0.1
2, 3, 7, 8-TCDD (Dioxin)	3 x 10 ⁻⁸
Tetrachloroethylene.....	0.005
Toluene.....	1.0
Total Trihalomethanes	0.080
Trichloroethylene	0.005
1, 2, 4-Trichlorobenzene.....	0.07
1, 1, 2-Trichloroethane.....	0.005
1, 1, 1-Trichloroethane.....	0.20
2, 4, 5-Trichlorophenoxypropionic Acid	0.05
(2, 4, 5-TP or Silvex)	
Toxaphene	0.003
Vinyl Chloride.....	0.002
Xylenes	10.0
Radionuclides (only apply to CWS)	
Alpha particles.....	15 picocuries per Liter (pCi/L)
Beta particles & photon emitters.....	4 millirems per year
Radium 226 & Radium 228 (combined).....	5 pCi/L
Uranium.....	30 ug/L

State of Illinois
Rod R. Blagojevich, Governor

Department of Public Health
Damon T. Arnold, M.D., M.P.H., Director



Maximum Levels for Contaminants in Public Water Supplies

The U.S. Environmental Protection Agency has established maximum levels for many contaminants in public water supplies. A public water supply is one that provides piped water for human consumption, and has at least 15 service connections or regularly serves at least 25 people daily at least 60 days per year. A public water system can be a community water system (CWS) or a non-community water system (NCWS). A CWS serves year-round residents (a permanent residential population). An NCWS serves a non-residential population. An NCWS also can be further classified as transient if it serves a different population each day (such as a highway rest stop, a restaurant, etc.) or non-transient if it serves the same population each day (such as a school or factory).

The maximum contaminant levels should not be exceeded in any community or non-transient, non-community public water supply. These standards are enforced through state and federal regulations. Even though the regulations cannot be enforced at private supplies, the principle inherent in adopting these limits for community and non-transient, non-community public water supplies, where the same persons consume the water every day, also applies to persons who obtain their water supplies from private wells. For further information concerning sampling or the health effects of a contaminant found in your drinking water, contact your local health department, the regional office of the Illinois Department of Public Health closest to you or the

Illinois Department of Public Health
 Division of Environmental Health
 525 W. Jefferson St.
 Springfield, IL 62761
 217-782-5830 or TTY (hearing impaired use only) 800-547-0466

To sample your well for some or all of these contaminants, a list of laboratories certified to perform these analyses can be obtained from:

Illinois Environmental Protection Agency
 1021 North Grand Ave. East
 P.O. Box 19276, MC #13
 Springfield, IL 62794-9276
 217-782-0610 or TTY (hearing impaired use only) 217-782-9143

Substance	Maximum Contaminant Level (MCL)
Inorganics	parts per million
Arsenic	0.010
Antimony	0.006
Asbestos	7 million fibers/liter
Barium.....	2.0
Beryllium	0.004
Cadmium.....	0.005
Chromium	0.1
Copper*.....	1.3
Cyanide	0.2
Fluoride	4.0
Lead*.....	0.015
Mercury.....	0.002
Nitrate	10.0 as nitrogen
Nitrite	1.0 as nitrogen
Selenium	0.05
Thallium.....	0.002
Turbidity.....	1.0 (NTU)+
+NTU=Nephelometric Turbidity Units	
*Measured in 90% of the samples at consumer's taps	
 Organics	
Alachlor.....	0.002
Atrazine.....	0.003
Benzene.....	0.005
Benzo (a) pyrene.....	0.0002
Bromate.....	0.010
Carbofuran	0.04
Carbon Tetrachloride	0.005
Chlorite.....	1.0
Chlorobezene.....	0.1
Dalapon.....	0.2
Dibromochloropropane (DBCP).....	0.0002
o-Dichlorobenzene.....	0.6
p-Dichlorobenzene.....	0.075
Dichloromethane (Methylene Chloride).....	0.005
1, 2-Dichloroethane	0.005
1, 1-Dichloroethylene	0.007
cis-1, 2-Dichloroethylene.....	0.07
trans-1, 2-Dichloroethylene	0.1
2, 4-Dichlorophenoxyacetic Acid (2, 4-D).....	0.07
1, 2-Dichloropropane	0.005
Dinoseb	0.007
Di (2-ethylhexyl) adipate.....	0.40
Di (2-ethylhexyl) phthalate.....	0.006
Diquat.....	0.02